



**MESA
COUNTY**

**COMMUNITY DEVELOPMENT DEPARTMENT
BUILDING DIVISION**

200 S. Spruce Street • PO Box 20,000-5005 • Grand Junction, Colorado • 81502
Telephone: 970.244.1631 • www.mesacounty.us/building

**Mesa County Building Inspection Division
Administrative Policy**

Issued by  12/23/2022
Darrell Bay, Chief Building Official

Topic:

This policy addresses the 2018 IECC Residential Mechanical Requirements.

Background:

The 2018 Energy Code residential requirements makes reference to a single set of design temperatures for Mechanical systems used in Mesa County.

Summation:

The wide variation in climate and elevation throughout Mesa County has led to the concerns of having improper heating and cooling systems based on the current established design temperatures. To account for differing conditions Mesa County will accept the following:

1. Mid-range temperatures of a Low 4 degrees and a high 98 degrees is allowed.
2. Manual J design shall be allowed to be done based on the minimum prescriptive requirements.
3. Equipment changes due to availability, documentation to be on site for equivalency verification.
4. Replacement unit's size shall not exceed and efficiency shall not be less than existing without complying with the requirements for a new installation.
5. Extreme cases contact Mesa County for individual consideration.